

# A Cross-layer Optimal Co-design of Control and Networking in Time-sensitive Cyber-Physical Systems

Mohammad H. Mamduhi, Dipankar Maity, *Member, IEEE*, John S. Baras, *Life Fellow, IEEE*, and Karl Henrik Johansson, *Fellow, IEEE*

**Abstract**—In the design of cyber-physical systems (CPS) where multiple physical systems are coupled via a communication network, a key aspect is to study how network services are distributed. To answer this adequately, we consider the coupling parameters between the control and network layers, and also the time-sensitive limitations and tolerances of the individual physical systems and the network. In this article, we first describe a cross-layer model for CPS wherein multiple stochastic linear processes are coupled via a shared network that provides a diverse range of cost-prone and capacity-limited services with distinct latency characteristics. Service prices are given such that low latency services incur higher communication cost, and prices remain fixed over a constant period of time but will be adjusted by the network for the future time periods. Physical systems decide to use specific services over each time interval depending on the service prices and their own time sensitivity requirements. Considering the service availability, the network coordinates resource allocation such that physical systems are serviced the closest to their preferences. Performance of individual systems are measured by an expected quadratic cost and we formulate a social optimization problem subject to time-sensitive requirements of the physical systems and the network constraints. From the formulated social optimization problem, we derive the joint optimal time-sensitive control and service allocation policies.

**Index Terms**—Cyber-physical systems, Latency-varying services, Cross-layer optimal design.

## I. INTRODUCTION

Many applications of CPS such as industrial automation and autonomous vehicles include multiple controlled dynamical systems with the feedback loops closed over a shared network infrastructure [1]. This poses novel challenges for the communication and control system design to support such coupled network of systems with stringent real-time requirements and tight inter-layer dependencies [2]. Recent evolution of 5G communication technology has provided a great potential to revisit the control and networking co-design paradigm in CPS by facilitating an adaptable communication medium that can conveniently adjust its service features depending on the user demands in, e.g., latency, reliability, bandwidth and security [3]. A strictly separate design of control and network layers

leads to conservative solutions and results in low quality of control as well as high cost of communication and computation usage. Hence, to efficiently fulfill the tight quality of control requirements and also to exploit the flexibility of the state-of-the-art communication technology, control and networking need to be co-designed in a cross-layer fashion [4], [5].

Providing a systematic and applicable joint design framework, however, is proven to be challenging due to, first, the tight integration of the physical and cyber layers through multiple coupling sources, and second, complexity of optimal solutions that make them non-scalable and intractable to apply on real-time CPS [6], [7]. Despite the noticeable progress including [8]–[10] to develop the co-design architectures, most of the results are obtained either under oversimplification of one of the CPS layers or under the traditional average-type constraints and stationary interfaces, where the former often results in eccentric design frameworks suitable for specific CPS models [11], and the latter leads to only asymptotic averaged performance guarantees [12]. From the communication perspective, control systems are typically abstracted as identical nodes that send/receive data to/from the network with QoS often defined as stationary requirements on data-rate, delay and packet loss [13], [14]. From the control perspective, the network capabilities are often simplified to single-hop channels with maximum data-rate, end-to-end constant or negligible delay and i.i.d. packet loss properties [15], [16].

In this paper, we describe a novel cross-layer interactive ecosystem for real-time CPS wherein heterogeneous physical systems are aware of the diverse network services while their time sensitivity requirements are shared with the network for an efficient service allocation. The major novelties are, first, the model of communication network and serviceability, and second, the sampling strategy which can schedule data packets to be delivered to the controller in future time-steps. Motivated by the state of the art communication technology, we assume network services provide multiple latency-varying transmission links, through which systems can close their sensor-to-controller loops subject to a given price. In a future-contract model, each system decides to pay the price for a certain network service for a known future time period. The system may change its service preference for the next future time period depending on the service price and its possibly changed communication requirements. This decision is made locally within each physical system by a separate controller that predicts the control cost over a finite horizon and selects the

M. H. Mamduhi, J. S. Baras, and K. H. Johansson are with the Division of Decision and Control Systems, KTH Royal Institute of Technology, Stockholm, Sweden, {mamduhi, baras, kallej}@kth.se

D. Maity is with the Guggenheim School of Aerospace Engineering, Georgia Institute of Technology, GA, USA, dmaity@gatech.edu

<sup>3</sup>J. S. Baras is with the Department of Electrical & Computer Engineering, The University of Maryland, MD, USA, baras@umd.edu

most efficient service which minimizes the combined control and communication cost. Requests of all systems are processed by the network where some requests might be differently serviced due to service limitations. Service prices are updated for the next time periods to avoid high traffic for certain services and also to incentivize the users to select expensive services only when necessary. Performance of each physical system is measured by quadratic control cost functions plus the communication service price. This urges the physical systems not always request the fastest transmission links because of higher communication prices. Service allocation is coordinated by the network such that the average sum of local performance discrepancies, resulting from network service limitations, is minimized across the physical layer over a finite time horizon. Given the described cross-layer interaction model, the joint optimal control and networking policies are derived.

**Notations:** In this article,  $E[\cdot]$ ,  $E[\cdot|\cdot]$  and  $\text{tr}(\cdot)$  denote, respectively, the expectation, conditional expectation and trace operators. We denote  $[x]_a^b \triangleq \max\{\min\{x, b\}, a\}$ . A matrix  $A \succ 0$  ( $\succeq 0$ ) is positive definite (positive semi-definite). For time varying variables, vectors, matrices and sets, superscripts denote the corresponding system and subscripts denote the time instance, e.g.,  $X_t^i$  belongs to system  $i$  and its content corresponds to time instance  $t$ . We also use  $X_{[t_1, t_2]}^i \triangleq \{X_{t_1}^i, \dots, X_{t_2}^i\}$  and  $X^i \triangleq \{X_0^i, X_1^i, \dots\}$ . For time-invariant matrices, we use subscript to show the belonging system. Moreover, for a general vector  $Y$  and a weight matrix  $Q$  of appropriate dimensions, we define  $\|Y\|_Q^2 \triangleq Y^\top Q Y$ .

## II. PROBLEM STATEMENT

We consider a class of CPS consisting of  $N$  dynamical systems coupled via a common communication network. Each physical system  $i \in \{1, \dots, N\}$  consists of a linear time-invariant (LTI) stochastic process  $\mathcal{P}_i$ , a time-sensitivity controller<sup>1</sup>  $\mathcal{S}_i$ , and a feedback controller  $\mathcal{C}_i$ . Let  $x_k^i \in \mathbb{R}^{n_i}$ ,  $u_k^i \in \mathbb{R}^{o_i}$  and  $w_k^i \in \mathbb{R}^{n_i}$  denote, respectively, the physical system's state, control signal and exogenous disturbance for the  $i^{\text{th}}$  system at time-step  $k$ . Dynamics of the plant  $\mathcal{P}_i$  is modeled as

$$x_{k+1}^i = A_i x_k^i + B_i u_k^i + w_k^i, \quad (1)$$

where  $A_i \in \mathbb{R}^{n_i \times n_i}$ ,  $B_i \in \mathbb{R}^{n_i \times o_i}$ , and the process noise  $w_k^i$  is zero-mean Gaussian distributed with variance  $\Sigma_{w^i} \succ 0$ , and  $w_k^i$  is assumed to be independent of  $w_\ell^j$  for all  $i \neq j$  or  $k \neq \ell$ . Initial states  $x_0^i$ 's are assumed to be randomly chosen from arbitrary i.i.d. zero-mean distributions with variance  $\Sigma_{x_0^i}$ , and are independent of  $w_k^j$ ,  $\forall j$  and  $k$ . The control cost of each physical system follows the finite horizon LQG function, i.e.,

$$J^i = E \left[ \|x_{t_f}^i\|_{Q_i^2}^2 + \sum_{k=0}^{t_f-1} \|x_k^i\|_{Q_i^1}^2 + \|u_k^i\|_{R_i}^2 \right], \quad (2)$$

where,  $t_f$  represents the final time of the time horizon  $[0, t_f]$ ,  $Q_i^1 \succeq 0$ ,  $Q_i^2 \succeq 0$  represent constant weights for the state, and  $R_i \succ 0$  is the control input weight matrix. Assume that the communication network has multiple capacity-limited service opportunities, each with a distinct latency and price, that




Fig. 1: Multiple LTI stochastic control systems close their loop over a shared service-limited network with a variety of latency-varying cost-prone transmission services over finite time periods of length  $T_p$ ,  $p = 1, \dots, m$ . ( $Z^{-d}$  denotes the delay operator.)

can be used by the physical systems. Let the network be comprised of  $D+1$  transmission links, together providing a spectrum of network services with different latencies, denoted by  $\mathcal{L} = \{s_d | d \in \mathcal{D} \triangleq \{0, \dots, D\}\}$  where  $d$  represents the link's corresponding latency. This means, if  $x_k^i$  is forwarded through the link  $s_d$  to the controller  $\mathcal{C}_i$  at a time-step  $k$ , then it will be received at  $\mathcal{C}_i$  at time-step  $k+d$ . Let the time horizon  $[0, t_f-1]$  be divided into  $m$  sub-intervals. We denote the  $p^{\text{th}}$  sub-interval by  $T_p$ ,  $p \in \{1, \dots, m\}$ , and  $T_p$  consists of  $\eta_p$  ( $\eta_p \in \mathbb{N}$ ) time-steps. We intuitively assume  $\eta_p > 1$ . Hence, the final time-step becomes  $t_f = \sum_{p=1}^m \eta_p$ . For the ease of the exposition, we assume that all sub-intervals have equal lengths, i.e.,  $\eta_p = \eta$ ,  $\forall p$ , and thus, the time-interval becomes  $T_p = [(p-1)\eta, p\eta-1]$ .

Let us denote the initial and the final time-steps of the sub-interval  $T_p$  by  $t_p^i = (p-1)\eta$  and  $t_p^f = p\eta-1$ , respectively. At the beginning of a sub-interval  $T_p$ , i.e., at time-step  $t_p^i$ , each physical system decides on its preferred service  $s_d \in \mathcal{L}$  to be its sensor-to-controller communication link. The service preference remains unchanged for the entire sub-interval  $T_p$  (i.e., until  $t_p^f$ ), and physical systems can select a different communication service only at the beginning of the next sub-interval  $T_{p+1}$ , i.e., at the time-step  $t_{p+1}^i$ .

During each sub-interval  $T_p$ , the service price for each transmission link  $s_d$  is denoted by  $\lambda_p^d$ , and is assumed to be fixed over the entire  $p^{\text{th}}$  sub-interval. They may, however, change from  $T_p$  to  $T_{p+1}$ . Prices are set such that links with lower latency are more expensive, i.e.,  $\lambda_p^0 \geq \dots \geq \lambda_p^D$ ,  $\forall p$ , and  $\Lambda_p \triangleq [\lambda_p^0, \dots, \lambda_p^D]^\top$  represents the service price vector for the sub-interval  $T_p$ . In general, using a higher latency service results in an increase in the average control cost (2).

Let  $\theta_t^i(d) \in \{0, 1\}$  denote whether system  $i$  is selected the transmission service  $s_d$  at time-step  $t$ , i.e., if  $\theta_t^i(d) = 1$ , then  $x_t^i$  is sent through the link  $s_d$  at time-step  $t$  to the controller  $\mathcal{C}_i$  and will be delivered at time  $t+d$ . Since the systems may change their service preferences only at time instances  $t_p^i$ 's,  $p \in \{1, \dots, m\}$ ,  $\theta_{t_p^i}^i(d) = \theta_{t_p^i+1}^i(d) = \dots = \theta_{t_p^f}^i(d)$ ,  $\forall d \in \mathcal{D}$ . Hence, the decision outcome of the time-sensitivity controller  $\mathcal{S}_i$ , generated only at time instances  $t_p^i$ , is represented as

$$\theta_{t_p^i}^i(d) = \begin{cases} 1, & s_d \text{ is selected to transmit } x_t^i, \forall t \in T_p \\ 0, & s_d \text{ is not selected, } \forall t \in T_p \end{cases} \quad (3)$$

<sup>1</sup>Time sensitivity controller indeed determines the time-varying value of a state information in terms of its influence in reducing a cost function.

We assume that each  $\mathcal{S}_i$  selects one and only one of the transmission services during each sub-interval  $T_p$ , i.e.,

$$\sum_{d=0}^D \theta_{i_p}^i(d) = 1, \quad \forall p = \{1, \dots, m\}, \quad \forall i \in \{1, \dots, N\}. \quad (4)$$

Since the decision outcome  $\theta_{i_p}^i(d), \forall d$ , is fixed for the entire sub-interval  $T_p$ , with a slight abuse of notation, we define the binary-valued  $\theta_{T_p}^i(d)$  as the representative for all  $\theta_{i_p}^i(d)$ ,  $t \in T_p$ , and  $\theta_{T_p}^i \triangleq [\theta_{T_p}^i(0), \dots, \theta_{T_p}^i(D)]^\top$ . The total service cost for the physical system  $i$  over the entire horizon  $[0, t_f]$  is  $\sum_{p=1}^m \eta \theta_{T_p}^i \Lambda^p$ , and the local cumulative cost for that system, that is a function of  $i^{\text{th}}$  system's local policies, becomes

$$J^i(u^i, \theta^i) = \mathbb{E} \left[ \|x_{t_f}^i\|_{Q_i}^2 + \sum_{k=0}^{t_f-1} \|x_k^i\|_{Q_i}^2 + \|u_k^i\|_{R_i}^2 + \sum_{p=1}^m \eta \theta_{T_p}^i \Lambda^p \right]. \quad (5)$$

Since simultaneously minimizing the network and the control cost are conflicting objectives, the optimization problem becomes a trade-off between the two urging decision-makers ( $\mathcal{C}_i, \mathcal{S}_i$ ) to search for the best combined strategy to minimize the accumulated cost of control and communication.

Network services are assumed to have capacity limitations such that not all systems can simultaneously be serviced through one specific link. To satisfy the service capacity constraints, allocated services to the physical systems may differ from the proffered ones ( $\theta_{T_p}^i$ ). The ultimate allocation of services is decided by a resource allocation unit in the network layer. Let  $\vartheta_t^i \triangleq [\vartheta_t^i(0), \dots, \vartheta_t^i(D)]^\top$  denote the resource allocation outcome for system  $i$  at time-step  $t$  such that  $\vartheta_t^i(d) = 1$  ensures that  $x_t^i$  will be forwarded to the controller  $\mathcal{C}_i$  via the service link  $s_d$  and will be received by  $\mathcal{C}_i$  at time-step  $t + d$ . Denoting the average capacity of a certain service  $s_d$  by  $0 < c_d < N$ , the capacity constraint is

$$\frac{1}{t_f} \sum_{k=0}^{t_f-1} \sum_{i=1}^N \vartheta_k^i(d) \leq c_d, \quad \forall d \in \mathcal{D}. \quad (6)$$

The main objective of this paper is to study how each physical system optimally selects  $\theta^i$  and  $u^i$  and how the network optimally reacts to the service selection  $\theta^i$ 's to construct appropriate  $\vartheta^i$ 's to satisfy the service constraints.

### III. CROSS-LAYER OPTIMAL DESIGN

#### A. Cross-layer policy makers

As depicted in Fig. 1, each system in the physical layer is steered by two local policy makers; a feedback controller  $\mathcal{C}_i$  and a time-sensitivity controller  $\mathcal{S}_i$ . We define  $\mathcal{I}_k^i$  and  $\tilde{\mathcal{I}}_{i_p}^i$  as the sets of available information for decision making for  $\mathcal{C}_i$  and  $\mathcal{S}_i$ , respectively. We note that  $\mathcal{C}_i$  generates the control input  $u_k^i$  at every time-step  $k$ , while  $\mathcal{S}_i$  generates  $\theta_{T_p}^i$  only at time instances  $t_p^i$ ,  $p \in \{1, \dots, m\}$ , hence, as suggested by the subscripts,  $\mathcal{I}_k^i$  is updated at every  $k$ , while  $\tilde{\mathcal{I}}_{i_p}^i$  is updated at every  $t_p^i$ . Having the information sets defined, we now introduce the causal policies  $\gamma_k^i : \mathcal{I}_k^i \mapsto \mathbb{R}^{o_i}$  and  $\xi_{i_p}^i : \tilde{\mathcal{I}}_{i_p}^i \mapsto \{0, 1\}^{D+1}$  of the system  $i$  that generate the control input at time-step  $k$  and service preferences for the sub-interval  $T_p$ , respectively, given the information sets  $\mathcal{I}_k^i$  and  $\tilde{\mathcal{I}}_{i_p}^i$ . That is  $u_k^i = \gamma_k^i(\mathcal{I}_k^i)$  and  $\theta_{T_p}^i = \xi_{i_p}^i(\tilde{\mathcal{I}}_{i_p}^i)$ .

We assume that a dedicated error-free acknowledgement channel exists to inform the controllers at every time-step  $k$  about the binary decision of the resource manager w.r.t. the preferred services of that system ( $\theta_{T_p}^i$ ), i.e.,  $\vartheta_k^i$  are known at  $\mathcal{C}_i$  at time-step  $k$  (see Fig. 1). Note that each controller uses a collocated estimator to estimate the current system state if it is not communicated. The decision on  $\vartheta_k^i$  is made at every time-step  $k$ , unlike  $\theta_{T_p}^i$  that is decided once for the entire sub-interval  $T_p$ . Ideally, network desires to service the dynamical systems exactly according to their preferences, i.e.,  $\forall k \in T_p$ ,  $\vartheta_k^i = \theta_{T_p}^i$ . If service limitations do not allow this, the allocated services are not necessarily the ones requested by some of the systems during some of the sub-intervals.

Similarly, we define  $\tilde{\mathcal{I}}_k$  as the set of available information for the network to allocate resources at time-step  $k$ . We introduce  $\pi_k : \tilde{\mathcal{I}}_k \mapsto \{0, 1\}^{(D+1)N}$  as the causal policy for computing  $\vartheta_k^i$ , i.e.,  $[\vartheta_k^1, \dots, \vartheta_k^N] = \pi_k(\tilde{\mathcal{I}}_k)^2$ .

#### B. Information structures of the policy makers

To characterize the information sets  $\mathcal{I}_k^i, \tilde{\mathcal{I}}_{i_p}^i, \tilde{\mathcal{I}}_k$ , we first assume that the local decision makers  $\mathcal{S}_i$  and  $\mathcal{C}_i$  have the knowledge of their own constant model parameters  $\mathcal{I}_{\text{cp}}^i \triangleq \{A_i, B_i, \Sigma_{w^i}, Q_i^1, Q_i^2, R_i\}$ . The resource allocation unit has access to  $\mathcal{I}_{\text{cp}}^i, \forall i$ . Before introducing the information interaction model, we state the following assumption:

*Assumption 1:* Resource allocation in the network layer is rendered independent of the local plant control inputs, i.e., none of the  $u_t^i, t < k$ , is incorporated in determining  $\vartheta_k^i$ .

This assumption declares a unidirectional interaction model between the plant control and the resource allocation policies, i.e., the control inputs  $u_{[0, k-1]}^i, \forall i$ , are not incorporated in computing  $\vartheta_k^i$ , however,  $u_k^i$ 's can be functions of  $\vartheta_{[k-D, k]}^i$ .

Considering the arbitrary time-step  $k$  belongs to an arbitrary sub-interval  $T_p$ , and noting the order of generating variables in one sampling cycle, ( $\theta_{T_p}^i \rightarrow \vartheta_k^i \rightarrow u_k^i \rightarrow x_{k+1}^i$ ), the information sets  $\mathcal{I}_k^i, \tilde{\mathcal{I}}_{i_p}^i$  and  $\tilde{\mathcal{I}}_k$  of the three decision makers  $\mathcal{C}_i, \mathcal{S}_i$  and the resource allocation, are as follows:

$$\mathcal{I}_k^i = \mathcal{I}_{\text{cp}}^i \cup \{\mathcal{Z}_{[0, k]}^i, \theta_{[0, k]}^i, \vartheta_{[0, k]}^i, u_{[0, k-1]}^i, \Lambda_{[1, p]}\} \quad (7)$$

$$\tilde{\mathcal{I}}_{i_p}^i = \mathcal{I}_{\text{cp}}^i \cup \{\theta_{[0, t_p^i-1]}^i, \vartheta_{[0, t_p^i-1]}^i, u_{[0, t_p^i-1]}^i, \Lambda_{[1, p]}\} \quad (8)$$

$$\tilde{\mathcal{I}}_k = \cup_{i=1}^N \{\mathcal{I}_{\text{cp}}^i \cup \{\theta_{[0, k]}^i, \vartheta_{[0, k-1]}^i\}\} \quad (9)$$

and,  $\mathcal{Z}_t^i = \{\vartheta_t^i(0)x_t^i, \vartheta_{t-1}^i(1)x_{t-1}^i, \dots, \vartheta_{t-D}^i(D)x_{t-D}^i\}$ . We also use  $\mathcal{I}^i = \{\mathcal{I}_k^i\}_{k=0}^{t_f-1}$ ,  $\tilde{\mathcal{I}}^i = \{\tilde{\mathcal{I}}_{i_p}^i\}_{p=1}^m$ , and  $\tilde{\mathcal{I}} = \{\tilde{\mathcal{I}}_k\}_{k=0}^{t_f-1}$ .

*Remark 1:* According to (7)-(9),  $u_k^i = \gamma_k^i(\mathcal{I}_k^i)$  is a function of  $\vartheta_{[0, k]}^i$ , but  $\pi_k$  does not incorporate  $u_{[0, k]}^i, \forall i$ , in computing  $\vartheta_k^i = \pi_k(\tilde{\mathcal{I}}_k)$ . The ultimate allocated resources to system  $i$  at a time  $k \in T_p$ , however, depend on  $\theta_{[0, k]}^i$ . Since  $\pi_k$  is a function of  $\theta_{[0, k]}^i$  for  $k \in T_p$  ( $\tilde{\mathcal{I}}_k$  includes  $\theta_{[0, k]}^i, \forall i$ ), control performance is indirectly considered in resource allocation as  $\theta_{[0, k]}^i$  are chosen by the physical systems in order to minimize the cumulative cost (5). This intuitively specifies that the *Assumption 1* is not too conservative in sense of separating resource allocation from control performance. Moreover, it

<sup>2</sup>With slight abuse of notation, to point the resource allocation outcome for a specific system  $i$ , we will sometimes write  $\vartheta_k^i = \pi_k(\tilde{\mathcal{I}}_k)$ .

leads to a considerable complexity reduction in computing the optimal policies  $\pi_k^*$  and  $\gamma_k^{i,*}$  (Section III-C), since the network does not need to have access to the entire control input history of all control systems, i.e.,  $u_{[0,k-1]}^i, i \in \{1, \dots, N\}$ .

### C. Cross-layer joint optimization problem

Given the information sets (7) and (8), the cumulative cost function (5), for a system  $i \in \{1, \dots, N\}$ , is expressed as

$$J^i(u^i, \theta^i | \mathcal{I}^i, \tilde{\mathcal{I}}^i) = \mathbb{E} \left[ \|x_{t_f}^i\|_{Q_2^2}^2 + \sum_{k=0}^{t_f-1} \|x_k^i\|_{Q_1^2}^2 + \|u_k^i\|_{R_i}^2 + \sum_{p=1}^m \eta \theta_{T_p}^{i\top} \Lambda_p | \mathcal{I}_k^i, \tilde{\mathcal{I}}_{t_p}^i \right]. \quad (10)$$

Note that, (10) represents the local cumulative cost function without considering the resource constraint (6), thus, no resource allocation decision  $\vartheta^i$  is present. The overall objective is to optimize the average performance of all systems under the constraint (6). If some of the service requests are handled differently in the network due to the constraint (6), i.e. when  $\vartheta_k^i$  is applied, the corresponding control input will be changed and the cumulative control cost  $J^i$  then becomes

$$J^i(u^i, \vartheta^i | \mathcal{I}^i, \tilde{\mathcal{I}}) = \mathbb{E} \left[ \|x_{t_f}^i\|_{Q_2^2}^2 + \sum_{k=0}^{t_f-1} \|x_k^i\|_{Q_1^2}^2 + \|u_k^i\|_{R_i}^2 + \sum_{p=1}^m \sum_{k \in T_p} \vartheta_k^{i\top} \Lambda_p | \mathcal{I}_k^i, \tilde{\mathcal{I}}_k \right]. \quad (11)$$

We formulate a social cost  $J$  as the average difference between the sum of  $J^i$ 's from the perspectives of the network (after resource allocation) and the physical systems, i.e.,

$$J = \frac{1}{N} \sum_{i=1}^N \mathbb{E} \left[ J^i(u^i, \vartheta^i | \mathcal{I}^i, \tilde{\mathcal{I}}) - \min_{u^i, \theta^i} J^i(u^i, \theta^i | \mathcal{I}^i, \tilde{\mathcal{I}}^i) \right]. \quad (12)$$

The aim is to derive the optimal policies  $\gamma_k^{i,*}(\mathcal{I}_k^i)$ ,  $\xi_{t_p}^{i,*}(\tilde{\mathcal{I}}_{t_p}^i)$  and  $\pi_k^*(\tilde{\mathcal{I}}_k)$  that jointly minimize  $J$  over the horizon  $[0, t_f-1]$

$$\min_{\gamma^i, \xi^i, \pi} J \quad (13a)$$

$$\text{s. t. } u_k^i = \gamma_k^i(\mathcal{I}_k^i), \theta_{T_p}^i = \xi_{t_p}^{i,*}(\tilde{\mathcal{I}}_{t_p}^i), \vartheta_k = \pi_k(\tilde{\mathcal{I}}_k) \quad (13b)$$

$$\sum_{k \in T_p} \vartheta_k^{i\top} \Lambda_p \leq \eta \theta_{T_p}^{i\top} \Lambda_p, \forall i, p \in \{1, \dots, m\} \quad (13c)$$

$$\frac{1}{t_f} \sum_{k=0}^{t_f-1} \sum_{i=1}^N \vartheta_k^i(d) \leq c_d, \forall d \in \mathcal{D}. \quad (13d)$$

The constraint (13b) ensures  $\gamma^i, \xi^i$  and  $\pi$  are admissible policies and measurable functions of the  $\sigma$ -algebras generated by their corresponding information sets, (13c) guarantees that re-allocated services impose no higher cost on the systems over the intervals  $T_p$ , and (13d) is the capacity constraint (6).

We propose a heuristic adaptive law to update the service prices for each sub-interval  $T_p$  to incentivize the systems to more evenly distribute their service requests, as follows:

$$\lambda_{p+1}^d = \left[ \lambda_p^d + \alpha_d \left( \sum_{i=1}^N \theta_{T_p}^i(d) - c_d \right) \right]_{\lambda_{\min}^d}^{\lambda_{\max}^d}, \quad (14)$$

where,  $\alpha_d \in \mathbb{R}_{\geq 0}$  is a network parameter to properly adjust the prices. The update law (14) ensures that  $\lambda_p^d \in [\lambda_{\min}^d, \lambda_{\max}^d]$ , where,  $\lambda_{\min}^d$  and  $\lambda_{\max}^d$  are known to all systems *a priori*<sup>3</sup>. The

<sup>3</sup>Search for the  $\alpha_d$ 's to find the optimal pricing mechanism is an interesting yet challenging problem, and beyond the scope of this work.

adaptive law (14) does not lead to an average degradation of (12) since, first, service prices are part of the local costs, and second, the prices for less-used services are decreased.

Theorem 1, for which we omit the proof due to space limitation, shows the structure of the optimal control law.

*Theorem 1:* Given the information sets  $\mathcal{I}_k^i, \tilde{\mathcal{I}}_{t_p}^i$  and  $\tilde{\mathcal{I}}_k$  in (7)-(9) and the problem (13a)-(13d), the optimal plant control law  $\gamma_k^{i,*}, \forall i$ , is of certainty equivalence form and control inputs are obtained from linear state feedback law as

$$u_k^{i,*} = \gamma_k^{i,*}(\mathcal{I}_k^i) = -L_k^{i,*} \mathbb{E}[x_k^i | \mathcal{I}_k^i], \quad i \in \{1, \dots, N\} \quad (15)$$

$$L_k^{i,*} = (R_i + B_i^\top P_{k+1}^i B_i)^{-1} B_i^\top P_{k+1}^i A_i, \quad (16)$$

where,  $P_T^i = Q_i^2$ , and  $P_k^i$  solves the Riccati equation

$$P_k^i = Q_i^1 + A_i^\top \left[ P_{k+1}^i - P_{k+1}^i B_i (R_i + B_i^\top P_{k+1}^i B_i)^{-1} B_i^\top P_{k+1}^i \right] A_i$$

*Theorem 2:* Consider the problem (13a)-(13d) and let  $\gamma^{i,*}, i \in \{1, \dots, N\}$  follow the certainty equivalence law (15)-(16). Given  $\tilde{\mathcal{I}}_{t_p}^i$  and  $\tilde{\mathcal{I}}_k$  in (8) and (9), the optimal time sensitivity control law is computed from the following constrained mixed-integer linear-programming (MILP)

$$\theta_{[k, t_f-1]}^{i,*} = \arg \min_{\xi_{[t_p^i, \tilde{t}_i^m]}^{i,*}} J^i(\gamma^{i,*}, \xi_{[t_p^i, \tilde{t}_i^m]}^{i,*}(\tilde{\mathcal{I}}_{[t_p^i, \tilde{t}_i^m]}^i)) = \quad (17)$$

$$\arg \min_{\xi_{[t_p^i, \tilde{t}_i^m]}^{i,*}} \sum_{t=k}^{t_f-1} \left[ \sum_{l=1}^{\tau_t^i} \sum_{j=l}^{\tau_t^i} \bar{b}_{j,t}^i \text{Tr}(\tilde{P}_t^i A_i^{l-1\top} \Sigma_w^i A_i^{l-1}) + \theta_t^{i\top} \Lambda_{\mu(k)} \right]$$

$$\text{s. t. } \forall i, t \in T_p, \theta_{t_p}^i = \dots = \theta_t^i = \dots = \theta_{t_p}^i = \theta_{t_p}^i = \xi_{t_p}^{i,*}(\tilde{\mathcal{I}}_{t_p}^i)$$

$$\bar{b}_{0,t}^i = \theta_t^i(0), \quad \bar{b}_{j,t}^i \leq \sum_{l=0}^j \theta_{t-j}^i(l), \quad j \in \{1, \dots, \tau_t^i\},$$

$$\sum_{l=0}^D \theta_t^i(l) = 1, \quad \sum_{j=0}^{\tau_t^i} \bar{b}_{j,t}^i = 1, \quad \sum_{j=t+2}^D \bar{b}_{j,t}^i = 0, \quad t \geq k,$$

$$\theta_s^i = \vartheta_s^i, \quad \forall s < k.$$

where,  $\mu(k) = p$  for  $k \in T_p$ ,  $\tau_t^i \triangleq \min\{D, t+1\}$ , and  $\tilde{P}_t^i = Q_i^1 + A_i^\top P_{t+1}^i A_i - P_t^i$ , and  $\bar{b}_{j,t}^i = [[1 - \theta_t^i(0)] \prod_{d=1}^{j-1} \prod_{l=0}^d [1 - \theta_{t-d}^i(l)]] / [\sum_{d=0}^j \theta_{t-j}^i(d)]$ . For notational correctness, we use the convention  $\prod_{d=d_1}^{d_2} a_d \triangleq 1$  and  $\sum_{d=d_1}^{d_2} a_d \triangleq 0, \forall d_1 > d_2$ . Subsequently, the optimal resource allocation law is computed from the following constrained MILP

$$\vartheta_{[k, t_f-1]}^{i,*} = \arg \min_{\pi_{[k, t_f-1]}} \sum_{i=1}^N \sum_{t=k}^{t_f-1} \left[ \vartheta_t^{i\top} \Lambda_{\mu(k)} \right] \quad (18)$$

$$+ \sum_{l=1}^{\tau_t^i} \sum_{j=l}^{\tau_t^i} \bar{b}_{j,t}^i \text{Tr}(\tilde{P}_t^i A_i^{l-1\top} \Sigma_w^i A_i^{l-1})$$

$$\text{s. t. } \frac{1}{t_f} \sum_{t=0}^{t_f-1} \sum_{i=1}^N \vartheta_t^i(d) \leq c_d, \quad \forall d \in \mathcal{D},$$

$$\sum_{t \in T_p} \vartheta_t^{i\top} \Lambda_p \leq \eta \theta_{T_p}^{i\top} \Lambda_p, \quad \forall i, p \in \{1, \dots, m\}$$

where,  $\bar{b}_{j,t}^i$  is similarly defined as  $\bar{b}_{j,t}^i$  with the exception that  $\theta_t^i$  is replaced by  $\vartheta_t^i$  for all  $i$  and  $t$  (see expression (21)).

*Proof 1:* Using the optimal control law (15)-(16), the cost-to-go  $V_k^i = \|x_{t_f}^i\|_{Q_2^2}^2 + \sum_{t=k}^{t_f-1} \|x_t^i\|_{Q_1^2}^2 + \|u_t^i\|_{R_i}^2$  is optimally computed as (see Theorem 1 and Proposition 1 in [17]):

$$V_k^{i,*} = \mathbb{E} \left[ \|x_k^i | \mathcal{I}_k^i\|_{P_k^i}^2 \right] \quad (19)$$

$$+ \mathbb{E} \left[ \|e_k^i\|_{P_k^i}^2 + \sum_{t=k}^{t_f-1} \|e_t^i\|_{P_t^i}^2 | \mathcal{I}_k^i \right] + \sum_{t=k+1}^{t_f} \text{tr}(P_t^i \Sigma_w^i),$$

where,  $e_k^i \triangleq x_k^i - \mathbb{E}[x_k^i | \mathcal{I}_k^i]$ , and  $\tilde{P}_t^i = Q_i^1 + A_i^\top P_{t+1}^i A_i - P_t^i$ . Moreover, the state estimate, at time-step  $k$ , is given as

$$\mathbb{E}[x_k^i | \mathcal{I}_k^i] = \sum_{j=0}^{\min\{D, k+1\}} \tilde{b}_{j,k}^i \mathbb{E}[x_k^i | x_{k-j}^i, u_0^i, \dots, u_{k-1}^i], \quad (20)$$

and, for all  $j \in \mathcal{D}$ , and  $k \geq j$ , we have

$$\tilde{b}_{j,k}^i = \prod_{d=0}^{j-1} \prod_{l=0}^d [1 - \vartheta_{k-d}^i(l)] [\sum_{d=0}^j \vartheta_{k-j}^i(d)]. \quad (21)$$

For,  $k < j$ ,  $b_{0,k}^i, \dots, b_{k,k}^i$ 's are defined as in (21),  $b_{k+1,k}^i = \prod_{d=0}^k \prod_{l=0}^d [1 - \vartheta_{k-d}^i(l)]$ , and  $b_{k+2,k}^i = \dots = b_{D,k}^i = 0$ .

Having (19), with  $k \in T_p$ , the optimal time sensitivity control law  $\xi_{[\tilde{t}_i^p, \tilde{t}_i^m]}^{i,*}$  is obtained by minimizing the cumulative cost  $J^i(u^{i,*}, \theta^i | \mathcal{I}^i, \tilde{\mathcal{I}}^i)$ , i.e.,  $\forall k \in [0, t_f - 1]$  and  $k \in T_p$

$$\theta_{[k, t_f - 1]}^{i,*} = \arg \min_{\xi_{[\tilde{t}_i^p, \tilde{t}_i^m]}^{i,*}} \mathbb{E} \left[ V_k^{i,*}(\gamma^{i,*}, \xi^i) + \sum_{t=k}^{t_f-1} \theta_t^{i\top} \Lambda_{\mu(k)} | \tilde{\mathcal{I}}_{\tilde{t}_i^p}^i \right].$$

Since  $\tilde{\mathcal{I}}_{\tilde{t}_i^p}^i \subseteq \mathcal{I}_k^i, \forall k \in T_p$ , and employing (20), one can compute  $\mathbb{E}[e_k^i e_k^{i\top} | \mathcal{I}_k^i | \tilde{\mathcal{I}}_{\tilde{t}_i^p}^i] = \mathbb{E}[e_k^i e_k^{i\top} | \tilde{\mathcal{I}}_{\tilde{t}_i^p}^i]$ , at  $\mathcal{S}_i$  side, to be:

$$\begin{aligned} \mathbb{E}[e_k^i e_k^{i\top} | \tilde{\mathcal{I}}_{\tilde{t}_i^p}^i] &= \sum_{l=1}^{\tau_k^i} \sum_{j=l}^{\tau_k^i} \tilde{b}_{j,k}^i \mathbb{E}[A_i^{l-1} w_{k-l}^i w_{k-l}^{i\top} A_i^{l-1\top}] \\ &= \sum_{l=1}^{\tau_k^i} \sum_{j=l}^{\tau_k^i} \tilde{b}_{j,k}^i A_i^{l-1} \Sigma_{k-l}^i A_i^{l-1\top}, \end{aligned}$$

where,  $\Sigma_{k-l}^i = \Sigma_{x_0^i}, k < l$ , and  $\Sigma_{k-l}^i = \Sigma_{w^i}, k \geq l$ . Having this with  $\tilde{\mathcal{I}}_{\tilde{t}_0^i}^i = \mathcal{I}_{\text{cp}}^i$ , we rewrite  $\mathbb{E}[V_0^{i,*}(\gamma^{i,*}, \xi^i) | \tilde{\mathcal{I}}_{\tilde{t}_0^i}^i]$  as follows

$$\begin{aligned} \mathbb{E}[V_0^{i,*}(\gamma^{i,*}, \xi^i) | \tilde{\mathcal{I}}_{\tilde{t}_0^i}^i] &= \|\mathbb{E}[x_0^i]\|_{P_k^i}^2 + \sum_{t=k+1}^{t_f} \text{tr}(P_t^i \Sigma_{w^i}) \\ &+ \text{tr}(P_0^i \sum_{l=1}^{\tau_0^i} \sum_{j=l}^{\tau_0^i} \tilde{b}_{j,0}^i A_i^{l-1\top} \Sigma_{x_0^i} A_i^{l-1}) \\ &+ \sum_{t=0}^{t_f-1} \text{tr}(\tilde{P}_t^i \sum_{l=1}^{\tau_t^i} \sum_{j=l}^{\tau_t^i} \tilde{b}_{j,t}^i A_i^{l-1\top} \Sigma_{t-l}^i A_i^{l-1}). \end{aligned}$$

As the only term in the last expression that is dependent on  $\theta_{[k, t_f - 1]}^{i,*}$  is the last term, we have for all  $k \in T_p$

$$\begin{aligned} \theta_{[k, t_f - 1]}^{i,*} &= \arg \min_{\xi_{[\tilde{t}_i^p, \tilde{t}_i^m]}^{i,*}} \mathbb{E} \left[ V_k^{i,*}(\gamma^{i,*}, \xi^i) + \sum_{t=k}^{t_f-1} \theta_t^{i\top} \Lambda_{\mu(k)} | \tilde{\mathcal{I}}_{\tilde{t}_i^p}^i \right] = \\ &\arg \min_{\xi_{[\tilde{t}_i^p, \tilde{t}_i^m]}^{i,*}} \sum_{t=k}^{t_f-1} \left[ \text{tr}(\tilde{P}_t^i \sum_{l=1}^{\tau_t^i} \sum_{j=l}^{\tau_t^i} \tilde{b}_{j,t}^i A_i^{l-1\top} \Sigma_{t-l}^i A_i^{l-1}) + \theta_t^{i\top} \Lambda_{\mu(k)} \right] \end{aligned}$$

Note that,  $\Lambda_p$  is known for  $\mathcal{S}_i$  assuming  $k \in T_p$  ( $k$  is the current time). The optimization problem is, however, solved from  $k$  to the final time  $t_f$  over which the prices may change from  $T_p$  to  $T_{p+1}$  while future price changes are not disclosed for  $\mathcal{S}_i$ 's at time  $k \in T_p$ . Hence, the system solves the local optimization problem considering the current prices, i.e.  $\Lambda_p$ , for the whole horizon  $[k, t_f]$ . At the beginning of the next sub-interval  $T_{p+1}$  when  $\mathcal{S}_i$  updates  $\theta_{T_{p+1}}^i$ , the adjusted price  $\Lambda_{p+1}$ , is considered until  $t_f$ . The constraints of the problem (17) are all linear and  $\theta_k^i$  is a binary variable, hence the problem is an MILP that is solved  $m$  times over the horizon  $[0, t_f]$ , once per each sub-interval  $T_p, p = \{1, \dots, m\}$ . The constraint  $\sum_{l=0}^D \theta_t^i(l) = 1$  ensures that only one transmission link is selected per-time, while the last two constraints are essential for correct indexes in the parameter  $\tilde{b}_{j,k}^i$  for  $k \geq D$  and  $k < D$ .

To find  $\pi^*$ , we take similar steps to compute  $\vartheta_k^{i,*}$  given the information set  $\tilde{\mathcal{I}}_k$ . We compute  $\mathbb{E}[V_k^{i,*}(\gamma^{i,*}, \pi) | \tilde{\mathcal{I}}_k]$  that results in a similar expression with the exception being  $\tilde{b}_{j,t}^i$  is replaced by  $\tilde{b}_{j,t}^i$  in (21). Hence, considering the price and resource constraints (13c)-(13d), we derive the optimal resource allocation from the following MILP, with  $k \in T_p$

$$\begin{aligned} \vartheta_{[k, t_f - 1]}^* &= \arg \min_{\pi_{[k, t_f - 1]}} \sum_{i=1}^N \mathbb{E} \left[ V_k^{i,*}(\gamma^{i,*}, \pi^i) + \sum_{t=k}^{t_f-1} \vartheta_t^{i\top} \Lambda_{\mu(k)} | \tilde{\mathcal{I}}_k \right] = \\ &\arg \min_{\pi_{[k, t_f - 1]}} \sum_{i=1}^N \sum_{t=k}^{t_f-1} \left[ \vartheta_t^{i\top} \Lambda_{\mu(k)} + \sum_{l=0}^{\tau_t^i} \sum_{j=l}^{\tau_t^i} \tilde{b}_{j,t}^i \text{Tr}(\tilde{P}_t^i A_i^{l-1\top} \Sigma_{w^i} A_i^{l-1}) \right]. \end{aligned}$$

The Theorems 1 and 2 show that under the assumption that  $\pi_k$  is independent of  $\gamma_{[0, k-1]}^i$ 's, we can decompose the problem (13a)-(13d) and solve it for the plant control policy separately, while the resource allocation and time-sensitivity control remain coupled through the adaptive service prices and capacity constraints. Note that, the complexity of MILPs (17) and (18) to compute the mentioned policies are of orders  $\mathcal{O}(NDm^2)$  and  $\mathcal{O}(NDt_f^2)$ , respectively, which suggests computationally feasible solutions for medium size CPS over finite horizons.

#### IV. NUMERICAL RESULTS

We consider a set of 20 homogeneous LTI systems with  $A_i = \begin{bmatrix} 1.01 & 0.2 \\ 0.2 & 1 \end{bmatrix}, B_i = \begin{bmatrix} 0.1 & 0 \\ 0 & 0.15 \end{bmatrix}, w_k^i \sim \mathcal{N}(\mathbf{0}, 1.5\mathbb{I}_{2 \times 2})$ , and  $Q_i^1 = Q_i^2 = R_i = \mathbb{I}_{2 \times 2}, \forall i$  and  $\forall k$ . We consider 6 network services with latencies  $\mathcal{D} = \{0, \dots, 5\}$ , where for  $\{s_0, \dots, s_4\}$  we assume  $c_d = 4$  and  $c_5 = 5$ . The maximum and minimum prices for  $\{s_0, \dots, s_5\}$  are  $\Lambda_{\max} = [31, 19, 12, 9, 5.5, 2.5]$  and  $\Lambda_{\min} = [19, 12, 9, 5.5, 2.5, 0.5]$ . Each sub-interval  $T_p$  consists of 10 time-steps, and  $t_f = 50$ , i.e.  $m = 5$ . The initial service costs  $\Lambda_1$  for the interval  $T_1 = [0, 9]$ , is  $[25, 13, 11, 7, 4, 1]$ , and prices are updated according to (14) with  $\alpha_d = 1, \forall d \in \mathcal{D}$ . We compare service request and allocation for the varying service costs, i.e.  $\alpha_d = 1$ , and constant service costs, i.e.  $\Lambda_p = \Lambda_1, \forall p$ . To capture the service usage, we define a network utilization quotient  $\rho_t(d), \forall t \in [0, t_f]$  and  $d \in \mathcal{D}$ , as follows

$$\rho_t(d) = \frac{1}{N(t+1)} \left[ \sum_{k=0}^t \sum_{i=1}^N \vartheta_k^i(d) \right]. \quad (22)$$

Thus,  $\rho_t(d)$  shows the usage percentage of the service  $s_d$  upto time  $t$ , and from the constraint (13d),  $\rho_{t_f-1}(d) \leq c_d/N$ .

In Fig. 2 we plot  $\rho_t(d)$  for time varying and constant service costs. In both cases, the usage for all services are the same for the first interval  $[0, 9]$ , as expected. Based on (14), prices for the services  $s_0, s_4, s_5$  increase whereas the prices for the rest decrease. These cost changes incentivize the systems to choose different services ( $\theta_t^i$ ), and consequently, the allocation of the links ( $\vartheta_t^i$ ) also changes because of (13c).

In particular, during the interval  $T_2 = [10, 19]$ , we observe a different usage in services  $s_4$  and  $s_5$  between the two scenarios. The increments in the service costs, however, do not necessarily change the utilization, for example, the increased cost of  $s_0$  did not change its usage. An interesting observation lies in the usage of services  $s_2$  and  $s_3$  for the final interval  $T_5 = [40, 49]$ . Since  $s_3$  is not used over  $T_3 = [30, 39]$ , its




Fig. 2: Usage of different services. The solid lines (—) correspond to the time varying service costs and the dotted lines with circles (· · · · ·) correspond to constant costs.




Fig. 3: Average link assignment variation

cost is reduced for  $T_4 = [40, 49]$ , however we still observe a decrease in its usage, and this is because  $s_2$  is still more efficient for many systems than  $s_3$ .

From this experiment, we notice that by adaptively changing the service costs, the utilization can be regulated, and the adaptive rule and its parameters play a significant role in regulating the usage. This is particularly a very interesting line of future research that how to *optimally* adapt the prices.

If the systems are served exactly as they request, each of them will incur a control cost of 61.1741 and a service cost of 1300. However, due to the capacity constraints, the systems do not obtain the desired service and the total control cost for the group becomes 22566.56 compared to  $61.1741 \times 20 = 1223.48$  – almost a twenty-fold increase. For the network, it would earn a total of  $1300 \times 20 = 26000$  if it could serve the exact requests. However, due to the capacity constraints, the network receives a total of 9916. The total cost due to the capacity limitation becomes  $22566.56 + 9916 = 32482.56$ , compared to the cost of  $1223.48 + 26000 = 27223.48$  with no capacity limitation.

We also studied the average deviation of the requested services from the assigned services. Let  $\vartheta^{i,*}$  denote the actual service assignment to the  $i$ -th system, and  $\theta^{i,*}$  denote its desired request, then the average deviation is calculated as

$$\Delta_t = \frac{\sum_{k=0}^t \sum_{i=1}^N \left| \sum_{d=0}^D d(\vartheta_k^{i,*}(d) - \theta_k^{i,*}(d)) \right|}{N(t+1)}, \quad (23)$$

where in (23),  $|\cdot|$  represents the absolute value. The results are plotted in Fig. 3, where we notice that  $\Delta_t$  is slightly higher with time varying costs as the updated costs persuade the systems to deviate further to adopt a new service.

## V. CONCLUSION

We propose a cross-layer model of CPS wherein multiple LTI stochastic systems are coupled via a shared network that provides a range of costly and capacity-limited services with distinct latencies. Service recipients (physical systems) select certain network services for a time period for a given price. Requests are processed by the network and services are allocated taking into account the users' demands and network limitations. Service prices are adjusted for future periods with the aim of receiving more evenly distributed service requests. We formulate a social cost minimized by cross-layer decision makers, where under mild assumptions on the information structure, we derive the resulting optimal policies taking into account their limitations, tolerances and constraints.

## REFERENCES

- [1] X. Yu and Y. Xue, "Smart grids: A cyberphysical systems perspective," *Proceedings of the IEEE*, vol. 104, no. 5, pp. 1058–1070, May 2016.
- [2] V. Gunes, S. Peter, T. Givargis, and F. Vahid, "A survey on concepts, applications, and challenges in cyber-physical systems," *KSII Transactions on Internet and Information Systems*, vol. 12, no. 12, 2014.
- [3] E. Molina and E. Jacob, "Software-defined networking in cyber-physical systems: A survey," *Computers & Electrical Engineering*, vol. 66, pp. 407 – 419, 2018.
- [4] Q. Zhu and A. Sangiovanni-Vincentelli, "Co-design methodologies and tools for cyber-physical systems," *Proceedings of the IEEE*, vol. 106, no. 9, pp. 1484–1500, 2018.
- [5] J. S. Baras, "A fresh look at network science: Interdependent multigraphs models inspired from statistical physics," in *Int. Symp. on Communications, Control and Signal Processing*, 2014, pp. 497–500.
- [6] K. D. Kim and P. R. Kumar, "Cyber-physical systems: A perspective at the centennial," *IEEE Proceedings*, vol. 100, no. Special Centennial Issue, pp. 1287–1308, 2012.
- [7] I. Horvth and B. H. M. Gerritsen, "Outlining nine major design challenges of open, decentralized, adaptive cyber-physical systems," in *33rd Computers and Information in Engineering Conference*, ser. International Design Engineering Technical Conferences, vol. 2B, 2013.
- [8] M. Chiang, S. H. Low, A. R. Calderbank, and J. C. Doyle, "Layering as optimization decomposition: A mathematical theory of network architectures," *IEEE Proceedings*, vol. 95, no. 1, pp. 255–312, 2007.
- [9] M. Klügel, M. H. Mamduhi, O. Ayan, M. Vilgelm, K. H. Johansson, S. Hirche, and W. Kellerer, "Joint cross-layer optimization in real-time networked control systems," *arXiv:1910.04631[eess.SY]*, 2019.
- [10] R. Mehta and D. K. Lobiyal, "Cross-layer optimization using two-level dual decomposition in multi-flow ad-hoc networks," *Telecommunications Systems*, vol. 66, no. 4, pp. 639–655, 2017.
- [11] M. Mamduhi, A. Molin, and S. Hirche, "Event-based scheduling of multi-loop stochastic systems over shared communication channels," in *21st International Symposium on Mathematical Theory of Networks and Systems*, 2014, pp. 266–273.
- [12] A. Molin and S. Hirche, "Price-based adaptive scheduling in multi-loop control systems with resource constraints," *IEEE Transactions on Automatic Control*, vol. 59, no. 12, pp. 3282–3295, 2014.
- [13] B. Li, Y. Ma, T. Westbroek, C. Wu, H. Gonzalez, and C. Lu, "Wireless routing and control: A cyber-physical case study," in *7th International Conference on Cyber-Physical Systems*, 2016, pp. 1–10.
- [14] A. Rajandekar and B. Sikdar, "A survey of MAC layer issues and protocols for machine-to-machine communications," *IEEE Internet of Things Journal*, vol. 2, no. 2, pp. 175–186, 2015.
- [15] F. Forni, S. Galeani, D. Nesić, and L. Zaccarian, "Event-triggered transmission for linear control over communication channels," *Automatica*, vol. 50, no. 2, pp. 490 – 498, 2014.
- [16] M. H. Mamduhi, D. Tolić, A. Molin, and S. Hirche, "Event-triggered scheduling for stochastic multi-loop networked control systems with packet dropouts," in *53rd IEEE Conference on Decision and Control*, 2014, pp. 2776–2782.
- [17] D. Maity, M. H. Mamduhi, S. Hirche, K. H. Johansson, and J. S. Baras, "Optimal LQG control under delay-dependent costly information," *IEEE Control Systems Letters*, vol. 3, no. 1, pp. 102–107, 2019.